



Hedwig Village Building Department

SUGGESTED GENERATOR PLAN SUBMITTAL CHECKLIST

ALONG WITH THE BUILDING PERMIT APPLICATION, GENERATOR PLANS MUST BE SUBMITTED IN DUPLICATE SETS AND INCLUDE THE FOLLOWING DOCUMENTS:

- Drawings of generator set slab which must include the site plan with the location of the generator
- Generator Manufacturer's specifications, including transfer switch information
- Plumbing riser diagram, including volume of natural gas needed for operation and any additions to the gas service
- Furnish load analysis for power that is serviced through the transfer switch. If a shed load system, then provide the load seen by utility power. Furnish load analysis for items serviced by the generator.
- Furnish an electrical one line diagram which included labeling of the ultimate fault current seen by all equipment and the fault current rating of all equipment
- For any additions or deletions from the appropriate code, check the Hedwig Village Code of Ordinance at www.thecityofhedwigvillage.com.
- Generator needs to be 3 feet from fence
- Structure distance is by manufacturer
- No height involved; set on 4 inch pad

